

Government of Karnataka
Department of Public Works

No : 2091, Executive Engineer / Public Works Department / Ramanagara Division / AE-
2-2021-22

Mobile No: 080 2273787, Fax: 080 27273789 Email- eepwdramanagara@gmail.com

Executive Engineer's Office

Public Works Department, Ramanagara Division

Ramanagara. 29/03/2022

To,

The Secretary,
Balaji Educational Trust (R.)
Balaji National Public School
Venkataiahyanapalya,
Opposite Sericulture Qtrs ,
Bychapur Road , Magadi Town,
Ramanagar Dist.


Dear Sir/Madam

Subject: Regarding issuance of building safety certificate for the ground floor and three storey building of Balaji National Public School constructed on a total area of 2 Acre 03 Gunta in Survey No.16/2 of Bychapur village, Kasaba Hobli, Magadi Taluk.

- Reference :
1. Government letter PWD No /59/BED /2019 dated 10-11-2021
 2. Date of their application : 24-05-2021.
 3. Letter No. 652/2021-22 dated 05-03-2022. from Assistant Executive Engineer, PWD No. 4 Sub Division, Magadi.
 4. This office letter No. 2051/2021-22 dated : 21-03-2022.

Regarding the above matter, Magadi Taluk, Kasaba Hobli, Bychapura Village, Assistant Executive Engineer , Public Works Department, No.4 Sub-Division, Magadi, is requested in reference (2)'s letter to issue Building Safety Certificate for the ground floor and three storey building of Balaji National Public School constructed on a total area of 2 acre 3 gunta on survey no. 16/2.

Bangalore University Civil Engineering Department, Bangalore. Assistant Executive Engineer with Public Works Department Sub-Division no. 4, Magadi and School Secretary jointly inspected the ground floor and three floors of the building and conducted Rebound Hammer Test and Ultrasonic Pulse Velocity Test and other tests and gave a report from Bangalore University Civil Engineering Department. It is reported in reference letter (3) that the said school building is "Structurally Stable".




Date:- On 18/03/2022 the said school building was jointly inspected by the Assistant Executive Engineer, Public Works Department, No. 4 Sub Division, Magadi, along with the School Secretaries and Registered Structural Engineer, Bangalore University, Bangalore.

Considering the certificate issued by the Department of Civil Engineering, Bangalore University that the ground floor and three storied building is structurally safe and the Assistant Executive Engineer, Public Work Department no. 4 In consideration of the report given and reference letter (4) indicating the valuation fee of the building, Rs. 46100 on 28-03-2022. As a result of submission of DD by this office, the building safety certificate has been issued stating that the ground floor and the three-storied building constructed in the said school premises are structurally stable and the following deficiencies are suggested to be adopted from time to time.


1. Plastering and Painting of existing roof slab.
2. Damp proofing works at all Floors.
3. Crack sealing or grouting works at visible structural cracks at some locations.
4. Crack sealing works at visible hairline cracks at some locations of wall and beam junctions.
5. Safety Measures for student and others.

Otherwise, regarding the non-structural elements (infrastructural facilities) of the proposed building, an objection letter should be obtained from the examination team consisting of civil engineer, health officer, revenue officer, psychologist, fire officer of the local organization and fire safety certificate should be obtained from the chief fire officer.



PRINCIPAL
ALAJI NATIONAL PUBLIC SCHOOL
Venkatayanapalya, Bychapura Road
Opp. to Siriculture Quarters
Magadi Town, Magadi Taluk - 562 120
Ramanagara District.

Yours faithfully
Executive Engineer
Public Works Department
Ramanagara Division
Ramanagara

Kannada to English Translated by



ATTESTED TRUE COPY


17/4/2024
RAVIKALA S.N. BALLI
ADVOCATE & NOTARY
MAGADI ROAD, MAGADI 562 120

